



SRI GODAVARI ENGINEERING CONSULTANTS (INDIA) PRIVATE LTD.,

+91 8309277491
+91 8985164416

AN ISO 9001-2015 & NABL ACCREDITED LABORATORY

115 - 14- 233, Konthamuru,
Rajahmundry-533 102, East Godavari Dist., A.P.
Branches : Visakhapatnam, Amaravathi

Ref No: SGE/RJY/WA/1854/05/2026

Date : 18.05.2026

To,

M/s Bhashyam Blooms E M School,
Door No .1-14-8 ,Ward No.14,
Tallapunta Road
Tanuku

West Godavari District - AP

Particular of Sample(S) :-

Nature of Sample : Water
Packing or Container : Plastic Bottles (5 Ltrs)
Date of Sample Receipt in the Lab : 13.05.2026
Period of Testing : 16.05.2026
Source of Material : Sample Supplied by Customer (Water Sample)
Condition of Sample : Acceptable

TEST RESULT OF WATER

Sl.No.	Physico-Chemical Parameters	Units	Tested Value	As per IS (10500 - 2012)	
				Required (Acceptable Limit)	Permissible Limit (in the absence of alternative source)
1	E Coli	100ml	NILL	No relaxation	No relaxation
2	Total Coliforms	100ml	<2	No relaxation	No relaxation
3	Colour	Co-Pt	2	5	15
4	Odour	---	Agreeable	Agreeable	Agreeable
5	Taste	---	Agreeable	Agreeable	Agreeable
6	Turbidity	NTU	0	0	5
7	Total Dissolved Solids	mg/lit	384	500	2000
8	pH	---	7.05	6.5-8.5	No relaxation
9	Aluminium	mg/lit	0.006	0.03	0.2
10	Ammonia as N	mg/lit	<0.5	0.5	0.5
11	Boran as B	mg/lit	0	0.5	1
12	Calcium as Ca++	mg/lit	50	75	200
13	Chloride as Cl ⁻	mg/lit	57	250	1000
14	Copper	mg/lit	0.001	0.05	1.5
15	Flouride as F ⁻	mg/lit	1.1	1	1.5
16	Residual Free Chlorine	10ml	Nil	0.2	2ppm
17	Total Iron as Fe	mg/lit	0	0.3	1
18	Magnesium as Mg++	mg/lit	24	30	100
19	Nitrate as NO ₃ ⁻	mg/lit	38	45	No relaxation
20	Sulphate as SO ₄ ⁻	mg/lit	48	200	400
21	Sulphide as H ₂ S	10ml	Negative	No relaxation	No relaxation
22	Total Alkalinity as CaCO ₃	mg/lit	304	200	600
23	Total Hardness as CaCO ₃	mg/lit	200	200	600
24	Electrical Conductivity	micromhos/cm	595	-	-
25	Chromium as Cr	mg/lit	0	0.05	0.05

REMARKS : The Above Sample is chemically Satisfied & fit for drinking purpose.

Note : The above said results are related only to the sample tested
Report should not be produced half or full without permission of laboratory

FOR SRI GODAVARI ENGINEERING

CONSULTANTS (INDIA) PRIVATE LTD.,

